

2023-2025 Lead water testing _____
Blue Creek Elementary

DATE:
6/6/2024

Sample #	Location	Time	Result Pb	Acceptable range Pb
2A	Sprayer by cauldron	445	14.4	≤ 5
24	room 14 bath	505	5.7	≤ 5
35	room 7 sink	516	12.1	≤ 5
45	room 3 bub	524	18.5	≤ 5
51	room 2 bub	529	9.3	≤ 5