

**2023-2025 Lead water testing
Boght Hills Elementary**

DATE:
9/30/2024

Sample #	Location	Time	Result Pb	Acceptable range Pb
BH-26	Womens faculty left sink	434	5.4	≤ 5
BH-45	Room 19 classroom sink	453	5.5	≤ 5