



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

October 30, 2024

Alan Levitus
North Colonie Central School District
735 Watervliet Shaker Rd
Latham, NY 12110

TEL: (518) 785-5771

Work Order No: 241023008

PO#: 54643

RE: Lead in Drinking Water
Boght Hills

Adirondack Environmental Services, Inc received 2 samples on 10/23/2024 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

A handwritten signature in black ink that reads "Tara Daniels". The signature is written in a cursive style.

Tara Daniels
Laboratory Director

North Colonie Central School District

Date: 30-Oct-24

Lead in Drinking Water

Lab WorkOrder: 241023008

Boght Hills

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers: ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 30-Oct-24

CLIENT: North Colonie Central School District
Project: Lead in Drinking Water
Boght Hills

LabWork Order: 241023008
PO#: 54643

Lab SampleID: 241023008-001 **Collection Date:** 10/22/2024 5:33:00 AM
Client Sample ID: BH Wom Fcclft - RT **Matrix:** WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: WB						
	(Prep: - 10/25/2024)					
Lead	3.8	1.0		µg/L	1	10/29/2024 11:16:14 AM

Lab SampleID: 241023008-002 **Collection Date:** 10/22/2024 5:34:00 AM
Client Sample ID: BH Rm 19 Bath - RT **Matrix:** WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: WB						
	(Prep: - 10/25/2024)					
Lead	4.4	1.0		µg/L	1	10/29/2024 11:19:49 AM