

**2023-2025 Lead Water Testing** \_\_\_\_\_  
**Southgate**

**DATE:**  
1/8/2025

Sample #	Location	Time	Result Pb	Acceptable range Pb
SG-31	Room 5 Bath	448	6.4	≤ 5
SG-44	Room 12 OLD FTN	506	23.4	≤ 5
SG-80	room 23 sink	544	7.5	≤ 5
SG-81	room 24 sink	546	7.3	≤ 5
SG-89	room 30 sink	556	15.6	≤ 5
SG-90	room 30 bubbler	556	6.7	≤ 5
SG-91A	rm 31 porc bub	559	9.8	≤ 5
SG-92	room 32 sink	601	10.3	≤ 5